

AMARAVATI METROPOLITAN REGION DEVELOPMENT AUTHORITY

Lenin Center, Governorpet, Vijayawada, Andhra Pradesh - 520002

Phone: 0866 – 2577475 Fax: 0866 – 2577357

File no.CRDA-14023/1/2016-DIR-LE-APCRDA

To

Environmental Engineer

A.P. Pollution Control Board

Regional Office, 4-5-4/5C, 4/3

Navabharath Nagar, Ring Road

Guntur - 522006

Sub: AMRDA – Consent for Operation (CFO) – 1st half yearly Compliance report, 2020 for Interim Government Complex Buildings, Velagapudi, Amaravati – Submission –Reg.

Ref: Order No. APPCB/VJA/ GNT/ 373/APCRDA/HO/CFO/2016 Dt: 31.10.16

In compliance with the relevant provisions of EC, CFE & CFO and in accordance with the Condition No.18 of Schedule B of CFO of Interim Government Complex at Velagapudi, Amaravati, the 1st half yearly compliance report for the year 2020 is being submitted along with enclosures for information.

Encl: 1st Half yearly Compliance report-2020
along with enclosures – 13 Pages.

(Dr.P.Lakshmi Narasimham,IAS)
Metropolitan Commissioner,AMRDA

Copy to:

The Joint Chief Environmental Engineer, A.P. Pollution Control Board, Zonal Office, Plot No. 41, Gurunanak Road, Opp. State Bank of Hyderabad, Sri Kanakadurga Officer's Colony, Vijayawada – 520 008 for information.

Compliance Status on CFO Conditions of Interim Government Complex
(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)
(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)
(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

1st Half Yearly Compliance Report for 2020

Schedule A:

S. No.	CFO Conditions	Compliance status
1	Any up-set condition in any industrial plant / activity of the industry, which result in, increased effluent / emission discharge and/ or violation of standards stipulated in this order shall be informed to this Board, under intimation to the Collector and District Magistrate and take immediate action to bring down the discharge / emission below the limits.	Noted, will inform accordingly.
2	The Authority shall carryout analysis of waste water discharges or emissions through chimneys for the parameters mentioned in this order on quarterly basis and submit to the Board.	Sample analysis results of waste water from outlet of the STP are furnished in Annexure 1.
3	The Authority shall put up two sign boards (6x4 ft. each) at publicly visible places at the main gate indicating the effluent discharge standards, air emission standards, hazardous waste quantities and validity of CFO and exhibit the CFO order at a prominent place in the factory premises.	It will be complied
4	Notwithstanding anything contained in this consent order, the Board hereby reserves the right and powers to review / revoke any and/or all the conditions imposed herein above and to make such variations as deemed fit for the purpose of the Acts by the Board.	Noted.
5	The Authority shall file the water cess returns in Form-I as required under section (5) of Water (Prevention and Control of Pollution)	Water cess has been abolished through Taxation laws (Amendment) Act, 2017

Compliance Status on CFO Conditions of Interim Government Complex

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)

(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

	Cess Act, 1977 on or before the 5th of every calendar month, showing the quantity of water consumed in the previous month along with water meter readings. The Authority shall remit water cess as per the assessment orders as and when issued by Board.	
6	The Authority shall submit Environment statement in Form V before 30th September every year as per Rule No.14 of E (P) Rules, 1986 & amendments there of	Noted.
7	The Authority shall make applications through Online for renewal of Consent (under Water and Air Acts) and Authorization under HWM Rules at least 120 days before the date of expiry of this order, along with prescribed fee under Water and Air Acts and detailed compliance of CFO conditions for obtaining Consent & HW Authorization of the Board. The Authority should immediately submit the revised application for consent to this Board in the event of any change in quantity of trade effluents & quantity of emissions.	<p>Noted.</p> <p>Renewal of Consent has been done through online and auto renewal was accorded by Order no. APPCB/VJA/GTR/373/APCRDA/HO/CFO/ 2017 Dt: 07.09.2017.</p> <p>Renewal of Consent has been done through online and auto renewal was accorded by Order no. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019.</p>
8	Any person aggrieved by an order made by the State Board under Section 25, Section 26, Section 27 of Water Act, 1974 or Section 21 of Air Act, 1981 may within thirty days from the date on which the order is communicated to him, prefer an appeal as per Andhra Pradesh Water Rules, 1976 and Air Rules 1982, to Appellate authority constituted under Section 28 of the Water(Prevention and Control of Pollution) Act, 1974 and Section 31 of the Air(Prevention and Control of Pollution) Act, 1981.	Noted.

Compliance Status on CFO Conditions of Interim Government Complex

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)

(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

Schedule B:

Water Pollution:

S. No.	CFO Conditions	Compliance status																										
1	The Authority shall treat the sewage to comply with the general standards for discharge of environmental pollutants as mentioned in Schedule-VI of the Environmental (Protection) Rules, 1986 and Amendments thereof:	Analysis results of STP outlet sample are furnished in Annexure 1.																										
	<table><tr><th>Outlet</th><th>Parameter</th><th>Concentration</th></tr><tr><td rowspan="11">1</td><td>Colour and odour</td><td>All efforts should be made to remove colour and unpleasant odour as far as practicable.</td></tr><tr><td>Suspended solids</td><td>200 mg/l</td></tr><tr><td>pH</td><td>5.5 to 9.0</td></tr><tr><td>Oil and grease</td><td>10 mg/l</td></tr><tr><td>BOD (3 days at 27°C)</td><td>100 mg/1</td></tr><tr><td>Arsenic (as As)</td><td>0.2 mg/1</td></tr><tr><td>Cyanide (as CN)</td><td>0.2 mg/1</td></tr><tr><td colspan="2">Radioactive materials:</td></tr><tr><td>(a) Alpha emitter</td><td>10⁻⁸ micro curie/ml</td></tr><tr><td>(b) Beta emitter</td><td>10⁻⁷ micro curie/ml</td></tr><tr><td>Bio-assay test</td><td>90% survival of fish after 96 hours in 100% effluent.</td></tr></table>		Outlet	Parameter	Concentration	1	Colour and odour	All efforts should be made to remove colour and unpleasant odour as far as practicable.	Suspended solids	200 mg/l	pH	5.5 to 9.0	Oil and grease	10 mg/l	BOD (3 days at 27°C)	100 mg/1	Arsenic (as As)	0.2 mg/1	Cyanide (as CN)	0.2 mg/1	Radioactive materials:		(a) Alpha emitter	10 ⁻⁸ micro curie/ml	(b) Beta emitter	10 ⁻⁷ micro curie/ml	Bio-assay test	90% survival of fish after 96 hours in 100% effluent.
	Outlet		Parameter	Concentration																								
	1		Colour and odour	All efforts should be made to remove colour and unpleasant odour as far as practicable.																								
			Suspended solids	200 mg/l																								
			pH	5.5 to 9.0																								
			Oil and grease	10 mg/l																								
			BOD (3 days at 27°C)	100 mg/1																								
			Arsenic (as As)	0.2 mg/1																								
			Cyanide (as CN)	0.2 mg/1																								
			Radioactive materials:																									
			(a) Alpha emitter	10 ⁻⁸ micro curie/ml																								
			(b) Beta emitter	10 ⁻⁷ micro curie/ml																								
Bio-assay test		90% survival of fish after 96 hours in 100% effluent.																										
2	The source of water being Krishna River. The following is the permitted water	Noted and is being complied.																										

Compliance Status on CFO Conditions of Interim Government Complex

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)

(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

	consumption:															
	<table><tr><th rowspan="2">S. No</th><th rowspan="2">Purpose</th><th colspan="2">Quantity (KLD)</th></tr><tr><th>Fresh water</th><th>Recycled water</th></tr><tr><td>1</td><td>Domestic & Gardening</td><td>300 KLD</td><td>120 KLD</td></tr><tr><td colspan="2">Total</td><td colspan="2">420.0 KLD</td></tr></table>	S. No	Purpose	Quantity (KLD)		Fresh water	Recycled water	1	Domestic & Gardening	300 KLD	120 KLD	Total		420.0 KLD		
S. No	Purpose			Quantity (KLD)												
		Fresh water	Recycled water													
1	Domestic & Gardening	300 KLD	120 KLD													
Total		420.0 KLD														
	Separate meters with necessary pipe-line shall be maintained for assessing the quantity of water used for each of the purposes mentioned above for Cess assessment purpose.															
3	The Authority shall commission own STP within three months. Till commissioning of own STP, the sewage generated shall be transported to the Ajit Singh Nagar STP of Municipal Corporation, Vijayawada, duly maintaining proper records indicating vehicle numbers, quantities etc. for further treatment and disposal.	Complied.														
4	Dual plumbing system shall be provided for reuse of the treated waste water for toilet flushing and other purposes.	The treated waste water from STP is being used for maintenance of greenery within the complex.														
5	No Untreated or treated waste water shall be discharged in any of the water bodies including Krishna River.	The treated waste water from STP is being used for maintenance of greenery within the complex.														
6	The Authority shall create separate budget fund and maintain separate account with adequate budget to meet operational cost of STP.	Noted.														

Compliance Status on CFO Conditions of Interim Government Complex
 (Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)
 (Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)
 (Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

Air Pollution:

S. No.	CFO Conditions	Compliance status					
7	<p>The Authority shall comply with ambient air quality standards of PM10 (Particulate Matter size less than 10µm) - 100 µg/m³; PM 2.5 (Particulate Matter size less than 2.5 µm) - 60 µg/m³; SO₂ - 80 µg/m³; NO_x - 80 µg/m³.</p> <p>Standards for other parameters as mentioned in the National Ambient Air Quality Standards CPCB Notification No.B-29016/20/90/PC1-1, dated 18.11.2009 shall be complied.</p> <table border="1"> <tr> <td rowspan="2">Noise Levels:</td><td>Day time</td><td>(6 AM to 10 PM) - 65 dB(A)</td></tr> <tr> <td>Night time</td><td>(10 PM to 6 AM) - 55 dB (A)</td></tr> </table>	Noise Levels:	Day time	(6 AM to 10 PM) - 65 dB(A)	Night time	(10 PM to 6 AM) - 55 dB (A)	The ambient air quality data of the complex is furnished in Annexure 2.
Noise Levels:	Day time		(6 AM to 10 PM) - 65 dB(A)				
	Night time	(10 PM to 6 AM) - 55 dB (A)					
8	<p>The Authority shall comply with emission limits for DG sets of capacity upto 800 KW as per the Notification G.S.R.520 (E), dated 01.07.2003 under the Environment (Protection) Amendment Rules, 2003 and G.S.R.448(E), dated 12.07.2004 under the Environment (Protection) Second Amendment Rules, 2004. In case of DG sets of capacity more than 800 KW shall comply with emission limits as per the Notification G.S.R.489 (E), dated 09.07.2002 at serial no.96, under the Environment (Protection) Act, 1986.</p>	Noted.					

Compliance Status on CFO Conditions of Interim Government Complex

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)

(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

General:

S. No.	CFO Conditions	Compliance status									
9	<p>The Authority shall maintain the following records and the same shall be made available to the inspecting officers of the Board:</p> <p>a. Quantity of Effluents generated, treated, recycled/reused and disposed for greenbelt development.</p> <p>b. Log Books for pollution control systems.</p> <p>c. Characteristics of ambient air, effluents and emissions.</p> <p>d. Hazardous/Non Hazardous solid waste generated and disposed.</p> <p>e. Inspection book.</p> <p>f. Manifest copies of Hazardous waste.</p>	Noted and records regarding effluents are being maintained.									
10	<p>The Authority shall dispose solid waste (Non Hazardous) as follows</p> <table border="1" style="margin-left: 20px;"> <thead> <tr> <th>S. No</th><th>Name of the Solid Waste</th><th>Quantity</th></tr> </thead> <tbody> <tr> <td>1</td><td>STP sludge</td><td>37.5 Kg / Day</td></tr> <tr> <td>2</td><td>Municipal Solid Waste / Garbage</td><td>2.25 TPD</td></tr> </tbody> </table>	S. No	Name of the Solid Waste	Quantity	1	STP sludge	37.5 Kg / Day	2	Municipal Solid Waste / Garbage	2.25 TPD	Noted.
S. No	Name of the Solid Waste	Quantity									
1	STP sludge	37.5 Kg / Day									
2	Municipal Solid Waste / Garbage	2.25 TPD									
11	The solid waste generated shall be properly segregated, transported and disposed scientifically as per Solid Waste Management Rules, 2016.	Noted. Segregated dry and wet waste is being collected and handed over to panchayat for final disposal.									
12	The solid waste generated shall be properly collected and segregated before disposal to the city municipal facility. Waste paper, cartons, thermo coal, plastic waste, glass, etc., shall be disposed to recycling units. The in-vessel bioconversion technique shall be used for composting the organic waste.	Noted. Segregated dry and wet waste is being collected and handed over to panchayat for final disposal.									
13	The Authority shall ensure development and meeting of not less than 10% of	An average 16% of the total complex energy									

Compliance Status on CFO Conditions of Interim Government Complex

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)

(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)

(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

	energy needs from the renewable energy sources like solar, wind, WTE, Biomass etc.	requirement is met from the roof top solar plant. It is complied.
14	The Authority shall ensure installation of solar panels at all buildings by allocating at least 1/3 of roof top for this purpose. Application for solar energy shall be incorporated for illumination of common areas, lighting for gardens and street lighting in addition to provision of solar water heating.	Two solar trees of total capacity 20.8 KW were installed near the parking space and roof top solar plant of 842.5 KW was also installed within the IGC.
15	The project falls within the "Amaravati — Capital City of Andhra Pradesh" which was accorded CFE vide dated 19.10.2015. The Authority shall comply with the CFE conditions applicable to this construction project.	Noted.
16	This CFO order is issued for the quantities and facilities mentioned in the CFE order dated 20.02.2016 issued for this project. The Authority shall obtain necessary Amendment to CFE order dated 20.02.2016 for the modifications in facility area, water consumption, and Waste water generation if required.	Noted.
17	The Authority shall comply with standards and directions issued by CPCB / MoEF & CC as and when notifications are issued.	Noted.
18	The Authority shall submit compliance report on the conditions mentioned in the consent order every six months to the Regional Office/ Zonal Office.	Noted.

Compliance Status on CFO Conditions of Interim Government Complex
(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)
(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)
(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

Schedule C [See rule 6] [Conditions of Authorisation for Occupier or Operator Handling Hazardous Wastes]:

S. No.	CFO Conditions	Compliance status
1	The authorized person shall comply with the provisions of the Environment (Protection) Act, 1986, and the rules made there under.	Noted
2	The authorization shall be produced for inspection at the request of an officer authorized by the State Pollution Control Board.	Noted
3	The person authorized shall not rent, lend, sell, transfer or otherwise transport the hazardous and other wastes except what is permitted through this authorization.	Noted
4	Any unauthorized change in personnel, equipment or working conditions as mentioned in the application by the person authorized shall constitute a breach of his authorization.	Noted
5	The person authorized shall implement Emergency Response Procedure (ERP) for which this authorization is being granted considering all site specific possible scenarios such as spillages, leakages, fire etc. and their possible impacts and also carry out mock drill in this regard at regular interval of time;	Noted. The mock drills are being taken up by the AP state disaster response and fire services department on regular basis.
6	The person authorized shall comply with the provisions outlined in the Central Pollution Control Board guidelines on "Implementing Liabilities for Environmental Damages due to Handling and Disposal of Hazardous Waste and Penalty".	Noted
7	It is the duty of the authorized person to take prior permission of the State Pollution Control Board to close down the facility.	Noted
8	The hazardous and other waste which gets generated during recycling or reuse or recovery or per-processing or utilization of imported hazardous or other wastes shall be treated and disposed of as per specific conditions of authorization.	Noted
9	An application for the renewal of an authorization shall be made as laid down under these Rules.	Noted

Compliance Status on CFO Conditions of Interim Government Complex
(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2016, Dated: 31.10.2016)
(Order No. APPCB/VJA/GNT/373/APCRDA/HO/CFO/2017, Dated: 07.09.2017)
(Order No. APPCB/VJA/GTR/373/APCRDA/HO/CFO/2019, Dated: 26.12.2019)

10	Any other conditions for compliance as per the Guidelines issued by the Ministry of Environment, Forest and Climate Change or Central Pollution Control Board from time to time.	Noted
11	Annual return shall be filed by June 30th for the period ensuring 31st March of the year.	Noted
12	The project shall not store hazardous waste for more than 90 days as per the Hazardous and Other Wastes (Management & Transboundary Movement) Rules, 2016.	Noted
13	The project shall store Used / Waste Oil and Used Lead Acid Batteries in a secured way in their premises till its disposal to the manufacturers / dealers on buyback basis.	Noted
14	The project shall maintain 7 copy manifest system for transportation of waste generated and a copy shall be submitted to concerned Regional Office of APPCB. The driver who transports hazardous waste should be well acquainted about the procedure to be followed in case of an emergency during transit. The transporter should carry a Transport Emergency (TREM) Card.	Noted
15	The project shall maintain proper records for Hazardous and Other Wastes stated in Authorization in Form-3 i.e., quantity of Incinerable waste, land disposal waste, recyclable waste etc., and file annual returns in Form-4 as per Rule 20 (2) of the Hazardous and Other Wastes (Management & Transboundary Movement) Rules, 2016.	Noted

P. Satish Dasgupta
Authorized Signature
11/11/20.



ANNEXURE - 1



Aqua Engineers and Consultants India Pvt Ltd
(An ISO 9001 : 2015 Certified Company)
Innovative Technologies For Sustainable Solutions...

TEST REPORT

Test Report No: AECIPL/L&T AP /2019-20/1640

Date: 31.03.2020

SAMPLE SUBMITTED BY THE CUSTOMER AND IDENTIFIED AS : TREATED SEWAGE WATER.

CUSTOMER NAME AND ADDRESS : Larsen & Toubro Construction,
AP Secretariat Interim Complex,
Velagapudi Village Guntur District
Andra Pradesh - 522503.

SAMPLE DESCRIPTION : Treated sewage water.

SAMPLE QUANTITY : 2 Litres

PACKING : Received in 1 Litre plastic Bottle.

SAMPLE RECEIVED ON : 23.03.2020

ANALYSIS STARTED ON : 24.03.2020

ANALYSIS COMPLETED ON : 30.03.2020

Tests	Test Method	Result	TNPCB limits
pH	4500-H+-B APHA 22 nd Edition 2012	7.4	5.5 - 9.0
Total suspended solids	2540-D- APHA 22 nd Edition 2012	11 mg/l	<30 mg/l
BOD 5 days @ 20 deg	5210-B APHA 22 nd Edition 2012	17 mg/l	<20 mg/l
COD	5220-B APHA 22 nd Ed. 2012	35 mg/l	250 mg/l

End of Report

Authorized Signatory

Page 1 of 1

Note: 1) this test report relates only to the items tested. 2) This test report shall not be reproduced anywhere except in full and in same format without the approval of the laboratory. 3) Sample is not drawn by us unless otherwise stated. 4) Retention period of tested samples is 15 days from the date of issue of test report unless otherwise specified.

Corporate Office :
Chennai
No.5 LCP Complex,
First Floor, Near Porur Tollplaza
Off 200 Feet By-Pass Road, Vanagaram,
Chennai - 600 095, Tamil Nadu, India.
Phone : +91-44-66444120

Branch Office
Bangalore
No.882, 4th Floor, Gaugadamas,
MES Ring Road, Mythala Nagar,
Bangalore - 560034
Karnataka, India

Branch Office
Kochi
No.33/198, Arakkadaven Road,
Alinchavadu, Vennala,
Kochi - 682028,
Kerala, India.



E-mail : sales@aquaengineers.in | Web : www.aquaengineers.in | CIN No. : U74999TN201111C080019.

K. Raja Ramesh
31/3/20

ANNEXURE - 2



CENTRAL POLLUTION CONTROL BOARD

CONTINUOUS AMBIENT AIR QUALITY

State Andhra Pradesh
City Amaravati
Station Secretariat, Amaravati - APPCB
Parameter NO₂, SO₂, CO, Ozone, PM₁₀, PM_{2.5}, NH₃, Benzene
AvgPeriod 24 Hours
From 01-03-2020T00:00:00Z 00:00
To 31-03-2020T12:33:59Z 00:00

Secretariat, Amaravati - APPCB						
Prescribed Standards		0-200	0-80	0-4	0-180	0-1000
Exceeding Standards		NA	NA	NA	NA	NA
From Date	To Date	NO ₂	SO ₂	CO	Ozone	PM ₁₀
01-03-2020 00:00	02-03-2020 00:00	8.52	19.71	0.49	51.55	56.54
02-03-2020 00:00	03-03-2020 00:00	12.16	24.35	0.58	46.82	61.41
03-03-2020 00:00	04-03-2020 00:00	10.51	23.31	0.57	44.65	63.64
04-03-2020 00:00	05-03-2020 00:00	12.2	17.43	0.55	38.44	57.35
05-03-2020 00:00	06-03-2020 00:00	7.56	20.46	0.48	26.82	31.39
06-03-2020 00:00	07-03-2020 00:00	5.33	16.26	0.49	30.32	30.95
07-03-2020 00:00	08-03-2020 00:00	6.76	12.63	0.52	26.4	25.39
08-03-2020 00:00	09-03-2020 00:00	8.14	29.26	0.49	25.45	22.4
09-03-2020 00:00	10-03-2020 00:00	10.27	16.99	0.54	17.25	23.69
10-03-2020 00:00	11-03-2020 00:00	7.59	25.08	0.48	23.95	21.84
11-03-2020 00:00	12-03-2020 00:00	5.73	21.34	0.48	24.54	18
12-03-2020 00:00	13-03-2020 00:00	5.54	16.91	0.49	25.64	26.25
13-03-2020 00:00	14-03-2020 00:00	6.04	14.46	0.46	25.91	34.99
14-03-2020 00:00	15-03-2020 00:00	8.51	22.86	0.5	27.28	44.24
15-03-2020 00:00	16-03-2020 00:00	7.68	21.85	0.47	29.49	44.82
16-03-2020 00:00	17-03-2020 00:00	9.19	20.71	0.58	30.64	46.79
17-03-2020 00:00	18-03-2020 00:00	8.81	21.01	0.64	36.15	48.7

18-03-2020 00:00	19-03-2020 00:00	9.43	14.66	0.58	31.11	36.47
19-03-2020 00:00	20-03-2020 00:00	8.23	20.38	0.55	31.9	35.2
20-03-2020 00:00	21-03-2020 00:00	7.1	25.88	0.49	28.72	28.21
21-03-2020 00:00	22-03-2020 00:00	5.12	24.96	0.49	25.96	26.51
22-03-2020 00:00	23-03-2020 00:00	4.36	20.78	0.49	26.97	43.33
23-03-2020 00:00	24-03-2020 00:00	4.66	25.4	0.46	28.99	50.61
24-03-2020 00:00	25-03-2020 00:00	4.84	21.1	0.46	28.31	39.79
25-03-2020 00:00	26-03-2020 00:00	4.32	19.08	1.51	27.85	35.6
26-03-2020 00:00	27-03-2020 00:00	4.98	18.74	0.73	29.78	43.64
27-03-2020 00:00	28-03-2020 00:00	4.74	21.41	0.2	38.19	51.74
28-03-2020 00:00	29-03-2020 00:00	4.74	21.97	0.25	41.35	51.58
29-03-2020 00:00	30-03-2020 00:00	5.16	19.13	0.36	38.49	53.33
30-03-2020 00:00	31-03-2020 00:00	5.24	22.28	0.39	42.38	58.93
31-03-2020 00:00	31-03-2020 12:33	4.7	21.75	0.17	30.14	46

Prescribed Standards
Exceeding Standards

0-1000
NA

0-400
NA

NA
NA

From Date	To Date	PM2.5	NH3	Benzene
01-03-2020 00:00	02-03-2020 00:00	33.53	12.66	0.26
02-03-2020 00:00	03-03-2020 00:00	39.88	12.82	0.26
03-03-2020 00:00	04-03-2020 00:00	39.84	12.79	0.27
04-03-2020 00:00	05-03-2020 00:00	35.36	12.14	0.27
05-03-2020 00:00	06-03-2020 00:00	19.54	10.8	0.12
06-03-2020 00:00	07-03-2020 00:00	18.54	10.2	0.13
07-03-2020 00:00	08-03-2020 00:00	13.94	10.53	0.13
08-03-2020 00:00	09-03-2020 00:00	10.19	8.32	0.1
09-03-2020 00:00	10-03-2020 00:00	13.06	9.42	0.1
10-03-2020 00:00	11-03-2020 00:00	10.45	9.47	0.09
11-03-2020 00:00	12-03-2020 00:00	10.65	8.77	0.03
12-03-2020 00:00	13-03-2020 00:00	13.51	10.57	0.01
13-03-2020 00:00	14-03-2020 00:00	18.58	8.95	0.02
14-03-2020 00:00	15-03-2020 00:00	23.83	9.87	0.12
15-03-2020 00:00	16-03-2020 00:00	25.93	9.88	0.18
16-03-2020 00:00	17-03-2020 00:00	26.83	10.83	0.18

17-03-2020 00:00	18-03-2020 00:00	29.83	9.93	0.18
18-03-2020 00:00	19-03-2020 00:00	20.28	9.28	0.11
19-03-2020 00:00	20-03-2020 00:00	18.11	9.37	0.11
20-03-2020 00:00	21-03-2020 00:00	15.07	10.06	0.07
21-03-2020 00:00	22-03-2020 00:00	14.08	8.58	0.04
22-03-2020 00:00	23-03-2020 00:00	25.86	10.17	0.06
23-03-2020 00:00	24-03-2020 00:00	26.19	8.63	0.07
24-03-2020 00:00	25-03-2020 00:00	17.42	7.58	0.09
25-03-2020 00:00	26-03-2020 00:00	16.71	7.61	0.08
26-03-2020 00:00	27-03-2020 00:00	23.64	7.9	0.14
27-03-2020 00:00	28-03-2020 00:00	25.47	8.21	0.09
28-03-2020 00:00	29-03-2020 00:00	24.92	7.88	0.08
29-03-2020 00:00	30-03-2020 00:00	26.79	7.94	0.13
30-03-2020 00:00	31-03-2020 00:00	29.86	7.95	0.09
31-03-2020 00:00	31-03-2020 12:33	24.18	8.47	0.06